

Exhibit B - Scope of Work for AMI Upgrade

There are two main components to upgrading the water meters to AMI water meters.

1. Replace the registers on approximately 3500 AMR water meters with CCSD-supplied AMI registers according to the instructions in Exhibit C – Process for Installing a New Register on a Water Meter.
2. Drill a 1-7/8” hole through the non-traffic plastic lids and mount the CCSD-supplied AMI antenna flush with the lid's surface. Non-plastic lids and lids in “traffic” areas (private driving or public walking) will be replaced with CCSD-supplied Fiberlyte lids pre-molded with a hole for mounting the antenna.

Notes:

1. The gophers tend to push dirt into the meter boxes, which must be removed to access the registers.
2. The meter locations vary in orientation from the edge of the property and the public right-of-way. Some meters are right on the property line, and others are located some distance from the property edge.
3. The CCSD will make a good effort to clear a three-foot radius around each meter for access and ease of locating the meter, but the contractor might need to perform some pruning or clearing of bushes, grass, dirt, and/or weeds for water meter access.
4. Bidders are recommended to familiarize themselves with the general, local, and site conditions and secure such additional or supplementary examinations, investigations, and data concerning local conditions that may affect the work.